


LEGEND

- XXXmm Ø EXISTING WATERMAIN LAID UNDER PREVIOUS AGREEMENT
- XXXmm Ø PROPOSED 150Ø HDPE WATERMAIN WITH PIPE SIZE
- XXXmm Ø PROPOSED 100Ø HDPE WATERMAIN WITH PIPE SIZE
- XXXmm Ø PROPOSED WATERMAIN UNDER CONSTRUCTION
- BB PROPOSED BOUNDARY BOX AND CONNECTION
- SV PROPOSED SLUICE VALVE
- ScV PROPOSED SCOUR VALVE
- H PROPOSED HYDRANT ON LINE TO STD-W-18
- Hyd PROPOSED HYDRANT OFF LINE TO STD-W-19
- AV PROPOSED AIR VALVE
- M PROPOSED WATER METER

NOTE: ALL BOUNDARY BOXES LOCATED IN THE TRAFFICKED AREAS IN THE MEWS/COURTYARDS AND SHARED AREAS ARE TO SIT ON 150MM OF CONCRETE AND BE SURROUNDED IN 150MM OF CONCRETE, WITH A 200MM CONCRETE PLINTH AROUND THE BOUNDARY BOX COVER FLUSH WITH THE TOP AND WEARING COURSE TO KNIT INTO THE PLINTH. A GRADE B COVER IS TO BE USED. 32mm SUPPLY PIPE TO BE USED FROM WATERMAIN TO BOUNDARY BOX AND 25mm SUPPLY CONNECTION FROM BOUNDARY BOX TO DWELLING.



This drawing should not be scaled. Dimensions to be verified on site.
Any discrepancies should be referred to the Engineer prior to work being put in hand.
This drawing is the property of Waterman Moylan Consulting Engineers Limited and is issued on the condition that it is not copied, reproduced, retained or disclosed to any unauthorized person, either wholly or in part without the consent in writing of Waterman Moylan Consulting Engineers Limited.
Block S, East Point Business Park, Dublin, D03 H3F4, Ireland t: +353 1 664 8900

- NOTES:**
1. DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
 2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.
 3. IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE THAT ALL WORKS ARE CONSTRUCTED IN ACCORDANCE WITH THE IRISH WATER CODE OF PRACTICE AND STANDARD DETAILS. THE CODE OF PRACTICE AND STANDARD DETAILS ARE AVAILABLE TO DOWNLOAD FROM THE IRISH WATER WEB SITE AT WWW.WATER.IE/CONNECTIONS/DEVELOPER-SERVICES/ WHERE THE DETAILS CONTAINED ON THIS DRAWING DIFFER FROM THE IRISH WATER CODE OF PRACTICE OR STANDARD DETAILS THIS MUST BE BROUGHT TO THE ATTENTION OF THE ENGINEER IMMEDIATELY. IRISH WATER STANDARDS WILL TAKE PRECEDENCE.
 4. WATERMANS SHALL BE LAID IN ACCORDANCE WITH THE LOCAL AUTHORITY / IRISH WATER SPECIFICATION FOR THE LAYING OF NEW WATERMANS AND BYLAWS WHICH OVER-RIDE THESE NOTES. THE CONSTRUCTION OF THE WATERMAIN SHALL BE IN ACCORDANCE WITH THE BEST CURRENT PRACTICE AND THE LATEST EDITIONS OF THE RELEVANT STANDARDS AND CODES OF PRACTICE.
 5. WATERMANS SHALL NOT BE LAID UNDER WALLS OR AREAS DESIGNATED FOR TREES/SHRUBS/FLOWERS.
 6. ALL PIPE MATERIALS SHALL BE IN ACCORDANCE WITH SECTION 3.9 OF THE IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE. WATERMANS SHALL BE EITHER DUCTILE IRON (DI) OR POLYETHYLENE (PE), WITH PE80 OR PE100 RATING (MDPE, HDPEOR HPPE). ALL PLASTIC WATER PIPES SHALL BE BLUE IN COLOUR.
 7. ALL SERVICE CONNECTIONS TO BE 25Ø HDPE(SDR-17).
 8. ALL WATERMANS UNDER ROADS OR AT ROAD CROSSINGS TO BE HDPE OR DUCTILE IRON.
 9. HDPE DISTRIBUTION PIPES TO BE PE-100(SDR-17).
 10. DUCTILE IRON PIPES TO IS EN 545 WITH C40 POWER RATING.
 11. AIR VALVE AND HYDRANTS COVERS, WHERE LOCATED IN GRASS AREAS, SHALL BE SURROUNDED BY A CONCRETE PLINTH, 200mm ALL ROUND AND 100mm DEEP FORMED WITH C20/25 CONCRETE, 20mm AGGREGATE SIZE, BEDDED IN CLAUSE 804 MATERIAL. THE PLINTH SHALL INCORPORATE MILD STEEL REINFORCED LINKS AND SHALL HAVE BULL-NOSE FINISH AROUND ITS EXTERNAL PERIMETER.
 12. THRUST BLOCKS SHALL BE PROVIDED AT EACH BEND ALONG THE COURSE OF THE WATERMAIN.
 13. PLANTING ADJACENT TO WATER INFRASTRUCTURE SHALL COMPLY WITH IRISH WATER STANDARD DETAIL STD-W-12A.
 14. HORIZONTAL AND VERTICAL SERVICE LAYOUT DISTANCES SHALL BE AS PER IRISH WATER STANDARD DETAIL STD-W-11.
 15. WATERMANS SHALL BE LAID UNDER FOOTPATHS PREFERABLY OR GRASS MARGINS WHERE APPROVED. NO PIPE, CONDUIT, CABLE OR OTHER SERVICE SHALL BE LAID LONGITUDINALLY OVER THE LINE OF A WATERMAIN. NO CABINET POLES, JUNCTION BOXES OR CHAMBERS SHALL BE CONSTRUCTED OVER A WATERMAIN.
 16. THE MINIMUM COVER TO A WATERMAIN SHALL BE 750mm, THE MAXIMUM COVER SHALL BE 900mm UNLESS NOTED OTHERWISE.
 17. CONNECTIONS TO THE MAINS WHICH ARE THE PROPERTY OF THE IRISH WATER CAN BE MADE BY THE IRISH WATER ONLY. NO OTHER PERSON MAY INTERFERE IN ANY WAY WITH THESE MAINS. SUCH CONNECTIONS WILL BE MADE BY IRISH WATER AT THE EXPENSE OF THE PERSONS REQUIRING THEM. THE ESTIMATED COST OF SUCH CONNECTIONS MUST BE LODGED WITH IRISH WATER BEFORE THE WORK IS UNDERTAKEN.

Rev	Date	Description	By	CHK
Amendments				

Project: PROPOSED RESIDENTIAL DEVELOPMENT AT OLD SLANE ROAD, DROGHEDA CO. LOUTH

Title: PHASE 3 WATERMAIN LAYOUT

Client: LAGAN HOMES TULLYALLEN LTD.

BLOCK S, EASTPOINT BUSINESS PARK, ALFIE BYRNE ROAD, DUBLIN D03 H3F4 IRELAND. Tel: (01) 664 8900
Email: info@waterman-moylan.ie www.waterman-moylan.ie

Status: **PLANNING**

Designed By	NS	Approved	MD	Waterman Ref	23-067
Drawn By	NS	Date	AUGUST 2025	Scales @ A1	1:500
Project - Originator - Volume - Level - Type - Role - Number					Revision
OSR-WMC-PH3-00-DR-C- 4300					-